


# Sensor Values Report

Report date: 6.5.2020 14:00:00 - 7.5.2020 14:00:00

Asset: VDW Repair Centre loggers Loggers



| Node | Sensor            | Unit | Min value | Max value | Avg value | Latest measurement | Latest value | State |
|------|-------------------|------|-----------|-----------|-----------|--------------------|--------------|-------|
| T4   | Ext Temperature 1 | °C   | 3.70      | 6.00      | 4.75      | 7.5.2020 14:02:30  | 5.50         | ●     |
| T5   | Ext Temperature 1 | °C   | 4.10      | 6.40      | 5.05      | 7.5.2020 14:02:30  | 5.90         | ●     |
| T6   | Ext Temperature 1 | °C   | 2.20      | 5.90      | 4.22      | 7.5.2020 14:01:30  | 4.90         | ●     |

Tekna doorgeefkoelkast met glasdeur

24-uurs meting, setpoint +5°C.

T4: bovenste plateau

T5: middelste plateau

T6 onder de onderste plateau